




NOBLESVILLE FIRE DEPARTMENT
FIRE PREVENTION BUREAU
INSPECTION DIVISION
MATT MITCHELL – DIVISION CHIEF
DARREL CROSS – FIRE INSPECTOR
RYAN FLORA – PT FIRE INSPECTOR



CITY OF NOBLESVILLE FIRE DEPARTMENT

FDC SIGNAGE DETAIL



- The sign shall be constructed out of a material that is not susceptible to degradation. The sign material shall be approved by the Fire Marshal.
- The sign lettering (and optional border) shall be RED in color.
- The sign shall be supported by an approved, permanent post or attached to the FDC pipe by an approved method.
- If freestanding, the top of the sign shall be mounted between 36" and 48" from finished grade.